



## O/o Civil Surgeon , Hisar

Mail-Id:- dhs.cshsr@hry.nic.in

Letter No. HSR/HI/2025/ 312

Dated: 21/11/2025

### PROFORMA REGARDING SAINTARY & HYGIENIC CONDITION

CERTIFICATE No. 2025/261

Date: 07-08-2025

It is certified that an inspection team headed by Medical Officer, PHC Dhansu (Name of Officers with designation) from Health Department, Hisar PHED inspected the Lakshay Public School, Dhanshu, Hisar (Name & Address of the school) on 06-08-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 1851 dated 18-07-2025 of PHED, District Water Testing Laboratory, Hisar (PHED Lab) certified that the Lakshay Public School, Dhanshu, Hisar (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year.

Signature with Seal :

  
Dy. Civil Surgeon (Health)  
20/11/25

Name: \_\_\_\_\_ : HISAR

Designation : \_\_\_\_\_

To

Lakshay Public School

Dhanshu, Hisar

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,HISAR

Website :- <https://phedharyana.gov.in/>

Memo No:- 1851

Date:- 21/07/2025

Subject : Physical / Chemical Examination Report of Water Sample

HC-516

Sample ID/Classification : HSR/04282/7/2025 / Private		Sample Details	Date & Time
Sender :	LAKSHAY PUBLIC SCHOOL	Collected By	RAMNIWAS
Location :	, DHANSU / WATER SUPPLY	Collection Date	18/07/2025 at 10:43
Sample Description :	Drinking Water	Received at lab	18/07/2025 at 12:36
Latitude / Longitude :	75.788047 / 29.215631	Analysis Start Date	18/07/2025
		Analysis End Date	21/07/2025
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.25	1 NTU	5 NTU	APHA 24th Edition -2130 B : 2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B : 2023
5	Total Dissolved Solids @ 180°C ± 2°C	207	500 mg/l.	2000 mg/l.	APHA 24th Edition -2540 C : 2023
6	Total Hardness as CaCO <sub>3</sub>	74.4	200 mg/l.	600 mg/l.	APHA 24th Edition -2340 C : 2023
7	Calcium as Ca	12.66	75 mg/l.	200 mg/l.	APHA 24th Edition-3500-Ca B : 2023
8	Magnesium as Mg	10.4	30 mg/l.	100 mg/l.	APHA 24th Edition -3500 Mg B : 2023
9	Total Alkalinity	60	200 mg/l.	600 mg/l.	APHA 24th Edition -2320 B : 2023
10	Chloride as Cl	48.21	250 mg/l.	1000 mg/l.	APHA 24th Edition -4500 Cl-B : 2023
11	Sulphate as SO <sub>4</sub>	50	200 mg/l.	400 mg/l.	APHA 24th -4500 SO <sub>4</sub> -E : 2023
12	Fluoride as F	0.109	1.0 mg/l.	1.5 mg/l.	APHA 24th Edition-4500F C : 2023
13	Iron as Fe	0.01	1.0 mg/l.	1.0 mg/l.	USEPA 45(126-43459) : 2018
14	Nitrate as NO <sub>3</sub>	11.23	45 mg/l.	45 mg/l.	APHA 24th Edition -4500 NO <sub>3</sub> D : 2023
15	pH @ 25°C	6.59	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B : 2023

Remarks :-

- The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- The test report can't be regenerated in whole or part thereof without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

  
 RAJEEV KUMAR, CHEMIST  
 DISTRICT WATER TESTING LABORATORY, HISAR  
 email:-chemist.hisar@phedharyana.gov.in